



## Applicable Standards

ANSI B16.1	Conforms to ANSI Class 125 flange drilling.
ANSI B16.5	Conforms to ANSI 150 flange drilling.
ANSI B16.42	Conforms to ANSI Class 150 flange drilling, body wall thickness and pressure-temperature ratings.
ANSI B16.104	Exceeds Class VI shutoff requirements.
API 609	Butterfly Valve Category A.
AWWA C504	Diameter of stainless steel shaft exceeds AWWA Class 75B standard. Body wall thickness exceeds the AWWA Class 150B standard for butterfly valve.
MSS SP-25	Markings and identification conform to the requirements.
MSS SP-67	Butterfly Valves
ISO 5211	Actuator Mounting
USCG	Category "A" Title 46, CFR, Part 56
ABS	American Bureau of Shipping

### **Flow Line Valve and Controls, L.L.C.**

110 Main Project Rd · Schriever, LA 70395 · Phone: 985-414-6004 · Toll Free 1-800-815-9226 · Fax 985-414-6072

[www.flowlinevalves.com](http://www.flowlinevalves.com)